




RIGHT HAND VIEW





Soft Starter Control Panel



- 1) Installer responsible for securely and structurally mounting the air barrier.

 2) Air Barrier is capable of spanning door without the need for intermediate support.
- 3) Top air intake is standard. Front intake available upon request.
- 4) Front motor placement is standard. Top motor placement available upon request.5) Unit is to be mounted 1" above the door header.
- 6) Remote lockable NEMA 1 enclosure, motor overload protection, with external reset, Soft starter is factory set with 5 sec start up.
 7) 2 Wall Mounts Provided.

- 8) Cabinet and accessories are powder coated ASA 49.
 9) Electrical connection and disconnect is by others.
- 10) 4 Extendable sliders provided.

CSA & CWB CERTIFIED

ENERSHIELD INDUSTRIES LTD 16821-113 AVENUE EDMONTON, ALBERTA T5M 2X2 PH (780) 482-4662 FAX (780) 482-4074 B-mail: info@enershield.ca www.enershield.ca	Engineer:	MEGASHIELD			MS-144
	Contractor:	Motor(s): 1 @ 25 hp TEFC 1800 RPM IP55			
				# Blowers	4
	Tag:	3 PHASE VOLTAGE	FLA	Air Velocity fpm-m/s	9900 /50.3
PROJECT:		208	68.7	Air Volume CFM-I/s	28,600 / 13,497
		460	31	Total hp/Kw	25 / 18.6
		575	25	Weight lbs/Kg	1320/600